

Letter No:-

180

Dated:-

21/03/2025

Government of Bihar

District Level Water Testing Laboratory Under, P.H.Div.Ariaria
Chemical and Bacteriological Report of Drinking Water Samples

District:- Ariaria

Water Sample are given by :- Rajesh Kumar

Water Sample Received on Date:17-03-2025

SL No	Location of Source	Test Result (in ppm)														
		NTU	Turbidity	P.H	Conductivity	Total Hardness	Total Alkalinity	Chloride	Iron	Calcium	Magnesium	Nitrate	T.D.S	As	F	Bacteria
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	
1	Mohani Devi Memorial School, Araria R.S, Araria	1	6.8	184	96	48	24	0.55	24	8	BDL	125	—	—	-Ve	
BIS 10500:2012 (second revision)	Desireable Limit	1	6.5-8.5	—	200	200	250	1	75	30	45	500	0.01	1	-Ve	
		5	NR	—	600	600	1000	NR	200	100	NR	2000	NR	1.5	**	
	Permissible Limit in absence of alternate source	5	NR	—	600	600	1000	NR	200	100	NR	2000	NR	1.5	**	

Note (i) BDL means below Detection Limit (ii) NR means no relaxation

Research Assistant/Chemist

P.H.Div.Ariaria


P.H. DIVISION

21/03/2025

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE**

No. 181Date : 21/03/2023

It is certified that an inspection team headed by MD. ROMAN HASAN
CHEMIST, DIST LAB P.H. Division Araria (Name of Officers
 with designation) from P.H. E-D (Name of
 Department/Office) inspected the MOHINI DEVI MEMORIAL SCHOOL, AR
ARARIA R.S. (Name & Address of
 the School) on 330170 and found that the Mohini Devi Memorial
School Araria R.S. (Name of school) has safe
 drinking water facilities for the students and members of staff of the institution and is maintaining
 the hygienic sanitation condition in the school building & the campus as per the norms
 prescribed by the Central/State/U.T Govt.

The above valid for a period of 1 yearSignature with Seal : 

Name :

MD ROMAN HASAN

Designation :

CHEMIST, P.H. Division
Araria

To

The Principal
Mohini Devi Memorial School
Araria, Bihar

(Name & Address of the Institution)